



Washington Yu Ying PCS - Lead in Water Test Results



FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Washington Yu Ying PCS	WS-066-003	Break Room	3	In staff lounge 314			WF-102020-066003-04	4/27/2021	FT-FY21-102020-066003-A	<1	FT-FY21-102020-066003-B	<1
Washington Yu Ying PCS	WS-066-008	Cooler	2	In hallway across from room 212	High	Left	WF-102020-066008-04	N/A	FT-FY21-102020-066008-A	Non-Op	FT-FY21-102020-066008-B	Non-Op
Washington Yu Ying PCS	WS-066-009	Cooler	2	In hallway across from room 212	Low	Right	WF-102020-066009-04	N/A	FT-FY21-102020-066009-A	Non-Op	FT-FY21-102020-066009-B	Non-Op
Washington Yu Ying PCS	WS-066-014	Cooler	1	In hallway across from room 129			WF-102020-066014-04	N/A	FT-FY21-102020-066014-A	Non-Op	FT-FY21-102020-066014-B	Non-Op
Washington Yu Ying PCS	WS-066-016	Food Prep Sink	1	In kitchen 126			WF-102020-066016-04	4/27/2021	FT-FY21-102020-066016-A	<1	FT-FY21-102020-066016-B	<1
Washington Yu Ying PCS	WS-066-017	Cooler	1	In hallway across from room 118	High	Left	WF-102020-066017-04	N/A	FT-FY21-102020-066017-A	Non-Op	FT-FY21-102020-066017-B	Non-Op
Washington Yu Ying PCS	WS-066-018	Cooler	1	In hallway across from room 118	Low	Right	WF-102020-066018-04	N/A	FT-FY21-102020-066018-A	Non-Op	FT-FY21-102020-066018-B	Non-Op
Washington Yu Ying PCS	WS-066-023	Bottle Filler	4	In hallway adjacent to room 410			WF-102020-066023-03	4/27/2021	FT-FY21-102020-066023-A	<1	FT-FY21-102020-066023-B	<1
Washington Yu Ying PCS	WS-066-024	Cooler	4	In hallway adjacent to room 410	High	Left	WF-102020-066024-03	N/A	FT-FY21-102020-066024-A	Non-Op	FT-FY21-102020-066024-B	Non-Op
Washington Yu Ying PCS	WS-066-025	Cooler	4	In hallway adjacent to room 410	Low	Right	WF-102020-066025-03	N/A	FT-FY21-102020-066025-A	Non-Op	FT-FY21-102020-066025-B	Non-Op
Washington Yu Ying PCS	WS-066-026	Bottle Filler	1	In classroom 107			WF-102020-066026-03	4/27/2021	FT-FY21-102020-066026-A	<1	FT-FY21-102020-066026-B	<1
Washington Yu Ying PCS	WS-066-027	Bottle Filler	1	In classroom 109			WF-102020-066027-03	4/27/2021	FT-FY21-102020-066027-A	<1	FT-FY21-102020-066027-B	<1
Washington Yu Ying PCS	WS-066-028	Bottle Filler	1	In classroom 118			WF-102020-066028-03	4/27/2021	FT-FY21-102020-066028-A	<1	FT-FY21-102020-066028-B	<1
Washington Yu Ying PCS	WS-066-029	Bottle Filler	1	In classroom 129			WF-102020-066029-03	4/27/2021	FT-FY21-102020-066029-A	<1	FT-FY21-102020-066029-B	<1
Washington Yu Ying PCS	WS-066-030	Bottle Filler	2	In classroom 205			WF-102020-066030-03	4/27/2021	FT-FY21-102020-066030-A	<1	FT-FY21-102020-066030-B	<1
Washington Yu Ying PCS	WS-066-031	Bottle Filler	2	In classroom 207			WF-102020-066031-03	4/27/2021	FT-FY21-102020-066031-A	<1	FT-FY21-102020-066031-B	<1
Washington Yu Ying PCS	WS-066-032	Bottle Filler	2	In classroom 212			WF-102020-066032-03	4/27/2021	FT-FY21-102020-066032-A	<1	FT-FY21-102020-066032-B	<1
Washington Yu Ying PCS	WS-066-033	Bottle Filler	2	In classroom 216			WF-102020-066033-03	4/27/2021	FT-FY21-102020-066033-A	<1	FT-FY21-102020-066033-B	<1
Washington Yu Ying PCS	WS-066-034	Bottle Filler	2	In classroom 220			WF-102020-066034-03	4/27/2021	FT-FY21-102020-066034-A	<1	FT-FY21-102020-066034-B	<1
Washington Yu Ying PCS	WS-066-035	Bottle Filler	2	In classroom 222			WF-102020-066035-03	4/27/2021	FT-FY21-102020-066035-A	<1	FT-FY21-102020-066035-B	<1
Washington Yu Ying PCS	WS-066-036	Bottle Filler	3	In hallway adjacent to room 313			WF-102020-066036-02	4/27/2021	FT-FY21-102020-066036-A	<1	FT-FY21-102020-066036-B	<1
Washington Yu Ying PCS	WS-066-037	Cooler	3	In hallway adjacent to room 313	High	Left	WF-102020-066037-02	N/A	FT-FY21-102020-066037-A	Non-Op	FT-FY21-102020-066037-B	Non-Op
Washington Yu Ying PCS	WS-066-038	Cooler	3	In hallway adjacent to room 313	Low	Right	WF-102020-066038-02	N/A	FT-FY21-102020-066038-A	Non-Op	FT-FY21-102020-066038-B	Non-Op

Greater than 5 ppb - Devices Requiring Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Washington Yu Ying PCS	WS-066-019	Health Suite	1	In health suite 116			WF-102020-066019-04	4/27/2021	FT-FY21-102020-066019-A	9.8	FT-FY21-102020-066019-B	2.4

*** At the request of the school, the health suite 116 is no longer a consumable water drinking source. The filter has been removed and "Do Not Drink" signage has been placed. There is no need to retest this device.